

Certificate

of

Type-Examination

Certificate No.: 12229005/AA/00

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical specifications as listed in Annex 2 of this certificate.
This certificate relates to an ISO/IEC guide 67 system 1a registration.

Product description: **Alarm Transmission Equipment**
Trademark: **See annex 3**
Family name: **--**
Type designation: **See annex 3**
Serial No: **See annex 3**
Hard-|Software release No: **LX20G_A3|1.11RC55**

Manufacturer: **EBS Sp. z o.o.**
Address: **ul. Bronislawa Czecha 59**
City: **04-555 Warszawa**
Country: **Poland**

This certificate is granted to:

Name: **EBS Sp. z o.o.**
Address: **ul. Bronislawa Czecha 59**
City: **04-555 Warszawa**
Country: **Poland**

This certificate has THREE Annexes.

Zevenaar, 08 July 2013



W.J.M. Jong
Manager Product Certification



Remarks and observations

The following conditions are applicable:

Equipment Security grade: 3
Equipment Environmental class: II
Equipment class: Fixed

According to EN 50131-1:2006 + A1:2009, this equipment can be applied in installed systems up to and including security grade 3.

ATS class: ATS 5 (D3, M3, T5, S2, I3)

This equipment includes GSM quad band radio module MC55i.

Only the DC versions of LX20G-3C and LX20G0-3C2 are certified in combination with the following control panel, keypad en power supply unit:

- * Product description: Control Panel
- * Trademark: TEXECOM
- * Type designation: Premier 48
- * Hardware Version: 02.13.0808
- * Software Version: 7.60

- * Product description: Housing and Power Supply Unit
- * Trademark: TEXECOM
- * Type designation: Premier PSU200
- * Hardware Version: 02.02.2005
- * Software Version: 2.0

- * Product description: Keypad
- * Trademark: TEXECOM
- * Type designation: RKP16 Plus
- * Hardware Version: 02.03.2005
- * Software Version: 9.4

Documentation lodged for this Certificate of Type-Examination

Test Reports:

- Laboratorium Badawcze Eltest: RG0155A, 03 November 2011
- Telefication B.V.: 20113749800rev3.0, 04 July 2013
- Telefication B.V.: 20113749801rev2.0, 04 July 2013

Product Documentation:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual
- Declaration of Variant

Technical Standards and Specifications

The product shows no non-compliances with:

- EN 50130-4: June, 2011
- EN 50136-1-1: January, 1998
- EN 50136-1-1/A1: August, 2001
- EN 50136-2-1: January, 1998
- EN 50136-2-1/A1: August, 2001

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

The product as described in this certificate includes the following type designations:

- Product description: Alarm Transmission Equipment
- Trademark: LX20G-3C
- Type Designation: LX20G-3C
- Hardware version: LX20G_A3
- Software version: 1.11RC55

- Product description: LX20G-3C with SMA GSM connector
- Trademark: LX20G-3C
- Type Designation: LX20G-3C2
- Hardware version: LX20G_A3
- Software version: 1.11RC55